



Strojirenský zkušební ústav, s.p., Brno, Česká republika
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

TEST CERTIFICATE

Number **O-B-01502-22 rev.1**

Customer **KOŁTON SPÓŁKA KOMANDYTOWA**
ul. Sosnowa 2
34-480 Jablonka
POLSKA

Product **Air/water heat pump – monobloc**

Type designation / Trade mark
Airkompakt p0916
Airkompakt p1118
Airkompakt p1522
Airkompakt p1926

Test methods **ČSN EN 14511-2:2019, ČSN EN 14511-3:2019,
ČSN EN 14511-4:2019, ČSN EN 12102-1:2018, EHPA Testing
regulation – Testing of Air/Water Heat Pumps, version 2.4a**

Basis of certificate **Test reports:**
39-16511/T of 2022-09-16
39-16511/H of 2022-09-16
Technical documents of KOŁTON SPÓŁKA KOMANDYTOWA

Temperature application **LOW TEMPERATURE,**
(Reference water temperature 35 °C)

MEDIUM TEMPERATURE
(Reference water temperature 55 °C)

Specification of conditions:

| | | | |
|--|-------------------|--|--------------|
| Compressor speed control | Fixed | Heating water volume flow rate (indoor heat exchanger) | Fixed |
| Outlet water temperature (indoor heat exchanger) | Variable | Source liquid volume flow rate (outdoor heat exch.) | - |
| Function | Reversible | | |



O-B-01502-22, page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

www.szutest.cz





Results:

| Model names | | Airkompakt p0916 (Tested) | Airkompakt p1118 (Not tested) | Airkompakt p1522 (Not tested) | Airkompakt p1926 (Not tested) |
|------------------------|--------------------------------|---------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| Temperature condition* | | | | | |
| A7W35 | Corrected heat capacity [kW] | 9.062 | 11.200 | 15.180 | 19.650 |
| | Effective power input [kW] | 1.950 | 2.599 | 3.667 | 4.226 |
| | Coefficient of performance [-] | 4.647 | 4.310 | 4.140 | 4.650 |
| | Control settings [-] | - | - | - | - |
| A7W55 | Corrected heat capacity [kW] | 8.428 | 11.200 | 12.890 | 17.400 |
| | Effective power input [kW] | 2.678 | 3.478 | 4.901 | 5.918 |
| | Coefficient of performance [-] | 3.148 | 3.220 | 2.630 | 2.940 |
| | Control settings [-] | - | - | - | - |
| A2W35 | Corrected heat capacity [kW] | 6.996 | 9.400 | 13.500 | 14.400 |
| | Effective power input [kW] | 1.911 | 2.473 | 3.562 | 3.891 |
| | Coefficient of performance [-] | 3.660 | 3.800 | 3.790 | 3.700 |
| | Control settings [-] | - | - | - | - |

Sound power level at condition A7/W55*:

| | | | | | |
|------------|---------|------------|------------|------------|------------|
| LWA | [dB(A)] | 62.9 ± 1.5 | 66.0 ± 1.5 | 68.0 ± 1.5 | 69.0 ± 1.5 |
|------------|---------|------------|------------|------------|------------|

Accuracy class

Engineering (2)

(*) Comment to abbreviated marking e.g. A7W35 B0/W35:

„A“ air, „7“ inlet temperature (dry-bulb temperature) in °C, „W“ water, „35“ outlet temperature in °C.

(Tested) This test sample was tested at the Testing Laboratory.

(Not tested) The technical data were declared by the Manufacturer according to the model range specifications and were not tested by the Testing Laboratory.

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2022-09-30

Milan Holomek

Head of Heat and Environment-Friendly Equipment Test Station

- END OF TEST CERTIFICATE -

